

Common Firestop Systems for AB/PVC

Typical UL Systems	Floor or Wall	Description
C-AJ-5079	Both	4-inch steel, iron or copper with ¾-inch AB/PVC
C-AJ-5133	Both	4-inch steel, iron or copper with 1-inch AB/PVC
C-AJ-5155	Both	4-inch steel, iron or 2-inch copper with ½-inch or ¾-inch AB/PVC
C-AJ-5193	Both	4-inch steel, iron or copper with ¾-inch AB/PVC
F-C-5043	Floor/Ceiling	4-inch steel, iron or copper with 1-inch AB/PVC
W-J-5012	Concrete Wall	4-inch steel, iron or copper with 1-inch AB/PVC
W-J-5055	Concrete Wall	4-inch steel, iron, or 2-inch copper with ½-inch or ¾-inch AB/PVC
W-L-5054	Gypsum Board Wall	4-inch steel, iron or copper with 1-inch AB/PVC
W-L-5122	Gypsum Board Wall	4-inch steel, iron, or 2-inch copper with ½-inch or ¾-inch AB/PVC