

## Common Firestop Systems for Fiberglass

Typical UL Systems	Floor or Wall	Description
C-AJ-5087	Both	24-inch steel, iron, 6-inch copper with 2-inch fiberglass
C-AJ-5058	Both	6-inch steel, iron or copper with 3-inch fiberglass
C-AJ-5138	Both	6-inch steel, iron or 4-inch copper with 2-inch fiberglass
C-AJ-5192	Both	4-inch steel, iron or copper with 1-inch fiberglass
F-C-5043	Floor/Ceiling	4-inch steel, iron or copper with 1-inch or 1½-inch fiberglass
W-J-5005	Concrete Wall	12-inch steel, iron or 4-inch copper with 2-inch fiberglass
W-J-5006	Concrete Wall	24-inch steel or iron with 3-inch fiberglass
W-J-5054	Concrete Wall	6-inch steel, iron or 4-inch copper with 2-inch fiberglass
W-L-5014	Gypsum Board Wall	12-inch steel, iron or 4-inch copper with 2-inch fiberglass
W-L-5033	Gypsum Board Wall	24-inch steel or iron with 3-inch fiberglass
W-L-5121	Gypsum Board Wall	6-inch steel, iron or 4-inch copper with 2-inch fiberglass