

Common Firestop Systems for Phenolic Foam

Typical UL Systems	Floor or Wall	Description
C-AJ-5176	Both	4-inch steel, iron or copper with 1-inch phenolic foam
C-AJ-5177	Both	4-inch steel, iron or copper with 1-inch phenolic foam
C-AJ-5187	Both	4-inch steel, iron or copper with 1-inch phenolic foam
C-AJ-5188	Both	4-inch steel, iron or copper with 1-inch phenolic foam
F-A-5026	Concrete Wall	12-inch steel or iron with 1½ - inch phenolic foam
C-AJ-5154	Both	6-inch steel, iron, or 4-inch copper with 3-inch cellular glass
W-J-5088	Concrete Wall	12-inch steel or iron with 1½ --inch phenolic foam
W-J-5112	Concrete Wall	2-inch steel, iron or copper with 1-inch phenolic foam
W-J-5113	Concrete Wall	2-inch steel, iron or copper with 1-inch phenolic foam
W-L-5221	Gypsum Board Wall	2-inch steel, iron or copper with 1-inch phenolic foam
W-L-5222	Gypsum Board Wall	2-inch steel, iron or copper with 1-inch phenolic foam